

FIRE PIPE OR DRY RISER PIPE

1. Picture of the product



Figure 1. Illustrative photo

2. Product description

Dry riser pipes can be attached directly on the wall or, using additional support parts, to the wall ladder. The top and bottom of the pipe must be supported properly. The lowest feet of the ladder are attached to the plinth. The length of the dry riser piping is dimensioned on a case-by-case basis.

The maximum length of individual pipe is 6,000 mm. Pipes longer than that are equipped with connections

that facilitate the installation and transport of the pipes. The shutoff valves speed up and increase the efficiency of the fire department's work in case of fire.